

Tratament chimic: CONSUM RIDICAT, LIPSA APA CALDA, ZGOMOT CENTRALE MURALE CONVENTIONALE



CHIMIA
INSTALATIEI
TERMICE

Probleme tratate: **CALCAR, MAGNETITA, IMPURITATI MECANICE**

Materiale: **CUPRU / OTEL / FONTA**

CHECK SERVICE




Verificare parametrul fluid

CLEANEX Fe-Cu PLUS



Solutie 15-20%
(cca 1.25kg / 6-7l apa)



Recirculare: 15-25 min



Monitorizare: pH<3

NEUTRALIZER ALCALIN



Solutie 1-4%
(cca 100g / 6l apa)



Recirculare: 5-10 min

APA DEMINERALIZATA



Clatire instalatie pana la pH 6.5-7.5
Incarcare cu apa demineralizata

INSTAL PROTECT



Dozare 1-2%
(cca. 1kg / 100l)