

Tratament chimic: CONSUM RIDICAT, LIPSA APA CALDA, ZGOMOT CENTRALE MURALE IN CONDENSARE, SCHIMBATOARE IN PLACI



CHIMIA
INSTALATIEI
TERMICE

Probleme tratate: CALCAR, OXIZI, IMPURITATI MECANICE

Materiale: INOX / ALUMINIU

CHECK SERVICE




Verificare parametrii fluid

CLEANEX Inox-AI PLUS



Solutie 15-20%
(cca 1.5kg / 6-7l apa)



Recirculare: 15-25 min



Monitorizare: pH<3

NEUTRALYZER ALCALIN



Solutie 1-4%
(cca 100g / 6l apa)



Recirculare: 5-10 min

APA DEMINERALIZATA



Clatire instalatie pana la pH 6.5-7.5
Incarcare cu apa demineralizata

INSTAL PROTECT



Dozare 1-2%
(cca. 1kg / 100l)