

Tratament chimic DEPUNERI MIXTE: CALORIFERE RECI CALORIFERE OTEL/FONTA, INSTALATII TEAVA NEAGRA



CHIMIA
INSTALATIEI
TERMICE


Probleme tratate: **MAGNETITA, NAMOL, CALCAR, MPURITATI MECANICE**

Materiale: **OTEL / FONTA**

CLEANEX INSTAL




Solutie 5-15%
(cca 5kg / 100l apa)



Recirculare: 10-15 min
fiecare calorifer/circuit



Monitorizare: pH>10




Golire solutie uzata
incarcare cu apa,
clatire pana la pH <9

CLEANEX TOTAL



Solutie 5-15%
(cca 5kg / 100l apa)

NEUTRALYZER ALCALIN




Recirculare: 10-15 min
fiecare calorifer/circuit




Monitorizare: pH<5



Golire solutie uzata,
incarcare cu solutie 1-4%
(cca 2kg / 100l apa)



Recirculare: 3-5 min
fiecare calorifer/circuit



Monitorizare:
pH 6.5 – 7.5