

# Tratament chimic: DEBIT REDUS PRIN CIRCUITE, ZONE RECI INSTALATII INCALZIRE IN PARDOSEALA



CHIMIA  
INSTALATIEI  
TERMICE

Probleme tratate: NAMOL, SARURI, MICRO-ORGANISME,

Materiale: ALIAJE CUPRU / PEX

## CHECK SERVICE




Verificare parametrul fluid

## CLEANEX TOTAL



Solutie 5-15%  
(cca 5kg / 100l apa)



Recirculare: 15-20 min  
fiecare circuit




Monitorizare: pH<3

## NEUTRALYZER ALCALIN



Solutie 1-4%  
(cca 1-2kg / 100l apa )



Recirculare: 5-10 min  
(fiecare circuit)

## APA DEMINERALIZATA



Clatire instalatie pana la pH 6.5-7.5  
Incarcare cu apa demineralizata

## BIO REDUCT



Dozare 1-2%  
(cca. 1kg / 100l)