

# Tratament chimic: CONSUM RIDICAT, LIPSA APA CALDA, ZGOMOT CENTRALE DE PARDOSEALA, BOILERE OTEL EMAILAT



CHIMIA  
INSTALATIEI  
TERMICE

Probleme tratate: CALCAR, MAGNETITA, IMPURITATI MECANICE

Materiale: CUPRU / OTEL / FONTA

## CHECK SERVICE




Verificare parametrul fluid

## CLEANEX Fe-Cu



Solutie 20-25%  
(cca 2.5kg / 10l apa)



Recirculare: 30-50 min




Monitorizare: pH<3

## NEUTRALIZER ALCALIN



Solutie 1-4%  
(cca 100g / 10l apa )



Recirculare: 5-10 min

## APA DEMINERALIZATA



Clatire instalatie pana la pH 6.5-7.5  
Incarcare cu apa demineralizata

## INSTAL PROTECT



Dozare 1-2%  
(cca. 1kg / 100l)