

Tratament chimic: CALORIFERE RUGINITE, PARTIAL RECI CALORIFERE OTEL/FONTA , INSTALATII SANITARE, TEAVA NEAGRA,



CHIMIA
INSTALATIEI
TERMICE

Probleme tratate: RUGINA, CALCAR, NAMOL

Materiale: OTEL / FONTA

CHECK SERVICE




Verificare parametrul fluid

CLEANEX RAD PLUS



Solutie 20-30%
(cca 20kg / 100l apa)



Recirculare: 20-30 min fiecare
circuit/calorifer (poate fi recirculata
si in sistem functional 2-3 zile)




Monitorizare: pH<5

NEUTRALYZER ALCALIN



Solutie 1-4%
(cca 1-2kg / 100l apa)



Recirculare: 5-10 min
(fiecare circuit/calorifer)

APA DEMINERALIZATA



Clatire instalatie pana la pH 6.5-7.5
Incarcare cu apa demineralizata

INSTAL PROTECT



Dozare 1-2%
(cca. 1kg / 100l)