

Tratament chimic: CALORIFERE PARTIAL RECI CALORIFERE OTEL/FONTA, INSTALATII TEAVA NEAGRA



CHIMIA
INSTALATIEI
TERMICE

Probleme tratate: **MAGNETITA, NAMOL, IMPURITATI MECANICE**

Materiale: **OTEL / FONTA**

CHECK SERVICE




Verificare parametrul fluid

CLEANEX INSTAL



Solutie 5-15%
(cca 5kg / 100l apa)



Recirculare: 15-20 min
(fiecare circuit/calorifer)




Monitorizare: pH>10

NEUTRALYZER ACID



Solutie 1-4%
(cca 2-3kg / 100l apa)



Recirculare: 5-10 min
(fiecare circuit/calorifer)

APA DEMINERALIZATA



Clatire instalatie pana la pH 6.5-7.5
Incarcare cu apa demineralizata

INSTAL PROTECT



Dozare 1-2%
(cca. 1kg / 100l)