

Tratament chimic: ZGOMOT, CALORIFERE PARTIAL RECI CALORIFERE ALUMINIU



CHIMIA
INSTALATIEI
TERMICE

Probleme tratate: **CALCAR, NAMOL, IMPURITATI MECANICE, GAZE**

Materiale: **ALUMINIU / ALIAJE ALUMINIU / CUPRU**

CHECK SERVICE




Verificare parametrul fluid

CLEANEX TOTAL



Solutie 5-15%
(cca 5kg / 100l apa)



Recirculare: 15-20 min
fiecare circuit/calorifer




Monitorizare: pH<3

NEUTRALYZER ALCALIN



Solutie 1-4%
(cca 1-2kg / 100l apa)



Recirculare: 5-10 min
(fiecare
circuit/calorifer)

APA DEMINERALIZATA



Clatire instalatie
pana la pH 6.5-7.5
Incarcare cu
apa demineralizata

INSTAL PROTECT



Dozare 1-2%
(cca. 1kg / 100l)

OXI REDUCT



Pentru calorifere Al
si instalatie Cu
Dozare 1-2%
(cca. 1kg/100l)