

# Tratament chimic: LIPSA CIRCULATIE, SUPRAINCALZIRE REPETATA PANOURI SOLARE



CHIMIA  
INSTALATIEI  
TERMICE

Probleme tratate: ANTIGEL DEGRADAT, DEPUNERI ORGANICE, PRAF

Materiale: CUPRU / ALUMINIU / STICLA

## CHECK SERVICE




Verificare parametrul fluid

## CLEANEX SOLAR



Solutie 20-50%  
(cca 5kg / 10l apa)



Recirculare: 30-50 min




Monitorizare: pH<5

## NEUTRALIZER ALCALIN



Solutie 1-4%  
(cca 150g / 10l apa )



Recirculare: 5-10 min



Clatire instalatie  
pana la pH 6.5-7.5

## SOLAR PROTECT S45



Incarcati instalatia  
Asigura protectia  
la -28°C  
(nu se dilueaza)

## CLEANEX PANSOL



Pulverizati o solutie de 15  
30% pe suprafata  
panourilor. Dupa 5-10 min  
clatiti cu apa abundent.